

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 01/17/2012  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>155654</b>		(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>01 , 02</b> B. WING _____		(X3) DATE SURVEY COMPLETED  <b>R</b> <b>01/12/2012</b>	
NAME OF PROVIDER OR SUPPLIER  <b>ENGLEWOOD HEALTH &amp; REHABILITATION CENTER</b>				STREET ADDRESS, CITY, STATE, ZIP CODE <b>2237 ENGLE RD</b> <b>FORT WAYNE, IN 46809</b>			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
{K 000}	<p>INITIAL COMMENTS</p> <p>A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey conducted on 12/01/11 was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.70(a).</p> <p>Survey Date: 01/12/12</p> <p>Facility Number: 000498 Provider Number: 155654 AIM Number: 100266110</p> <p>Surveyor: Amy Kelley, Life Safety Code Specialist</p> <p>At this PSR survey, Englewood Health and Rehabilitation Center was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety from Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2.</p> <p>This one story facility was determined to be of Type V (111) construction and was fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors and areas open to the corridors. The facility has a capacity of 67 and had a census of 64 at the time of this survey.</p> <p>Quality Review by Robert Booher, Life Safety Code Specialist-Medical Surveyor on 01/13/12.</p>			{K 000}			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.